



City of Cleveland
Justin M. Bibb, Mayor

Department of Finance
Division of Purchases & Supplies
601 Lakeside Avenue, Room 128
Cleveland, Ohio 44114-1080
216/664-2620 • Fax: 216/664-2177
www.cleveland-oh.gov

February 23, 2026

ADDENDUM 1

BID TITLE: File No.12-26 Valves and Appurtenances 20 inch and Larger

BID DUE: Thursday, March 12, 2026 at 12 o'clock noon (Eastern Time)

Attention Bidders:

We have been requested to issue the addendum for the following:

Please ensure that a copy of this addendum is included and returned with the bid specifications furnished to you by this office, as it will have the same force and effect as if it were part of the specifications originally issued.

1. Answer questions received.

If you have any questions regarding the attached, please contact Jules Gilliam at jgilliam@clevelandohio.gov. Thank you for your prompt attention and assistance in this matter. Also, please ensure that copy of this addendum is included and returned with the bid specifications furnished to you by this office, as it will have the same force and effect as if it were part of the specifications originally issued.

Signature of Potential Bidder & Name of Company

Today's Date

Thank you,
Donia Patterson, Assistant Administrator
Purchases & Supplies
CC:

**CITY OF CLEVELAND, OHIO
DEPARTMENT OF PUBLIC UTILITIES**

**VALVES AND APPURTENANCES 20-INCH AND LARGER
FILE NO. 12-26**

ADDENDUM NO. 1

The bid due date is March 12, 2026 and bids must be date stamped before 12:00 p.m. that day.

The last day for questions is March 3, 2026 by 12:00 p.m.

Answer to question received:

1. Will the ductile spec (C-515) be considered for these large valves in place of C-500/C-509?

Answer: No. AWWA C515 valves will not be considered in place of AWWA C500 or C509 valves. Bid per group AWWA specifications listed.