



City of Cleveland
Justin M. Bibb, Mayor

Department of Finance
Division of Purchases & Supplies
601 Lakeside Avenue, Room 128
Cleveland, Ohio 44114-1080
216/664-2620 • Fax: 216/664-2177
www.cleveland-oh.gov

March 24, 2026

ADDENDUM 1

BID TITLE: File No.21-26 2026 A- Water Main Renewal and Sewer Replacement

BID DUE: Wednesday, April 1, 2026 at 12 o'clock noon (Eastern Time)

Attention Bidders:

We have been requested to issue the addendum for the following:

Please ensure that a copy of this addendum is included and returned with the bid specifications furnished to you by this office, as it will have the same force and effect as if it were part of the specifications originally issued.

1. Issue sign-in sheet from the pre-bid meeting.
2. Answers to questions received by the last day for questions.

If you have any questions regarding the attached, please contact Jules Gilliam at jgilliam@clevelandohio.gov. Thank you for your prompt attention and assistance in this matter. Also, please ensure that copy of this addendum is included and returned with the bid specifications furnished to you by this office, as it will have the same force and effect as if it were part of the specifications originally issued.

Signature of Potential Bidder & Name of Company

Today's Date

Thank you,
Donia Patterson, Assistant Administrator
Purchases & Supplies
CC:

2026-A Water Main Renewal and Sewer Replacement

Addendum No. 1 – File No. 21-26

The bid due date is April 1, 2026 and bids must be date stamped no later than 11:59 a.m. that day.

A copy of the sign-in sheet from the pre-bid meeting is attached.

Answers to questions received by the last day for questions:

1. Under Section 01 29 00 Measurement and Payment. Paragraph 1.3 Payment Items in Volume 2, Part D – Technical Specifications; the Bid Item Subparagraphs on Pages 1 through 10 specify that Repair of pavement is included in the Bid Item Scope of Work, this includes the Water main, Hydrants, Water Service Connections, Valves, Catch Basins & VCP, and Sewer Laterals. Beginning on page 33 with Item 611A Pipe Culverts, Sewers, and Drains; Pavement repair is not specified in work included, nor is it specified in plans sheets 87 or 88. Is repair of pavement to be included in the Item Price for Pipe Culverts, Sewers, and Drains?

Answer: Pavement repair is included under water main items (bid items 12-21; drawings sheet 8). Pavement repair is not included for sewer work to avoid double-counting. Water main and sewer main work should occur prior to final pavement restoration.

2. Plan sheets 72-82 for the Restoration Plan, the shaded areas depicted for Trench Restoration Limits contradicts the requirement for 2' cutbacks on each side of the trench per Restoration Details VIII on plans sheet 152 and Pavement and Walks note 10. "WHERE LESS THAN 2' OF PAVEMENT WILL REMAIN BETWEEN CURB AND TRENCH OVERCUT LIMITS, CONTRACTOR SHALL REMOVE AND REPLACE FULL DEPTH PAVEMENT TO CURB. THIS SHALL BE INCLUDED IN THE COST BID PER LINEAR FOOT OF WATER MAIN." on plans sheet 4. Recommend the shaded area on the restoration sheets either conform to the detailed requirement in scale or be removed from sheets 72-82.

Answer: The shaded areas indicating trench restoration are for illustrative purposes only.

**CITY OF CLEVELAND
DEPARTMENT OF PUBLIC UTILITIES
NON-MANDATORY PRE-BID MEETING
Thursday, March 12, 2026
9:30 a.m.**

**2026-A Water Main Renewal and Sewer Replacement
and 2026-B Water Main Renewal**

SIGN-IN SHEET

	REPRESENTATIVE NAME (PLEASE PRINT)	COMPANY NAME (PLEASE PRINT)	TELEPHONE NUMBER	E-MAIL ADDRESS (PLEASE PRINT CLEARLY)
	Mike Guinto	Terrace Construction	216-739-3170	mfg@terraceconstruction.com
	Scott Veley	DPU		
	DeAndrea Pruitt	DPU		
	Reggie Hill	DPU		
	Charlie Rosol	DPU		
	Jennifer Wiman	OEO		
	Jules Gilliam	COC		
	Martin Reese	CWD		
	Sandra Stack	CWD		
	Cecilia Mazzei	WPC		